

CERTIFICATE OF ANALYSIS

Fulmont Laboratory & Consultants
 219 Noonan Road
 Ft. Johnson, New York 12070
 Phone/Fax: (518) 842-5171

Date: November 20, 2016

Sample ID: 16096

Date Analyzed: November 17, 2016

WO Number: 160927096

Customer: Ft. Plain Central School District

Collection Date: September 27 & 29, 2016

Address: 25 High Street, Ft. Plain, New York 13339

Collection Time: See Chart

Sample Location: Harry Hoag Elementary School

Collected by: Angelo E. Finateri

Sample Point: See Chart

Potable: Yes

Water Source: Municipal Water

Grab/Composite: Grab

Chlorinated: Yes

Receipt Temp:

Sample #	Harry Hoag School Sample Point		Collection Time	Date	Test Result (mg/l)	MCL (mg/l)	Qualifier	Method
46	Sink	Kitchen by exterior door	5:03 AM	9/27/16	0.009	0.015		SM3113B
81	Tap	Kitchen under sink	5:02AM	9/27/16	0.007	0.015		SM3113B
9	Sink	Kitchen middle	5:04AM	9/27/16	0.004	0.015		SM3113B
83	Sink	Kitchen by convection oven	5:04AM	9/27/16	0.007	0.015		SM3113B
99	Sink	Kitchen island	5:05AM	9/27/16	0.007	0.015		SM3113B
63	Outlet	Kitchen filler for steam kettle	5:20AM	9/27/16	0.002	0.015		SM3113B
48	Sink	Kitchen rest room	5:07AM	9/27/16	0.016	0.015	X	SM3113B
102	Sink	Kitchen dish washer room	5:09AM	9/27/16	0.036	0.015	X	SM3113B
43	Sink	#19 counter top	5:10AM	9/27/16	0.074	0.015	X	SM3113B
52	Sink	#19 basin	5:10AM	9/27/16	0.004	0.015		SM3113B
47	Fountain	Athletic hallway by cafeteria	5:11AM	9/27/16	<0.001	0.015		SM3113B
71	Sink	#18 boys phys ed office	5:30AM	9/29/16	0.035	0.015	X	SM3113B
80	Sink	#18 boys rest room	5:13AM	9/27/16	0.017	0.015	X	SM3113B
72	Fountain room	fitness room between boys and girls locker	5:14AM	9/27/16	0.008	0.015		SM3113B
88	Sink	#17 girls rest room	5:15AM	9/27/16	0.015	0.015	X	SM3113B
119	Sink	#17 girls phys ed office	5:16AM	9/27/16	0.019	0.015	X	SM3113B
44	Sink	#15 snack shack	5:22AM	9/27/16	0.013	0.015		SM3113B
110	Sink	#1 counter	5:25AM	9/27/16	0.008	0.015		SM3113B
116	Fountain	#1 same counter	5:25AM	9/27/16	0.006	0.015		SM3113B
94	Sink	#1 rest room	5:24AM	9/27/16	0.016	0.015	X	SM3113B
82	Sink	#2 rest room	5:27AM	9/27/16	0.008	0.015		SM3113B
92	Fountain	#2 counter	5:27AM	9/27/16	0.002	0.015		SM3113B
39	Sink	#2 counter	5:28AM	9/27/16	0.002	0.015		SM3113B
12	Sink	#3 counter	5:29AM	9/27/16	0.002	0.015		SM3113B

CERTIFICATE OF ANALYSIS

Fulmont Laboratory & Consultants
 219 Noonan Road
 Ft. Johnson, New York 12070
 Phone/Fax: (518) 842-5171

Date: November 20, 2016
Sample ID: 16096
Date Analyzed: November 17, 2016
WO Number: 160927096

Customer: Ft. Plain Central School District
Address: 25 High Street, Ft. Plain, New York 13339
Sample Location: Harry Hoag Elementary School
Sample Point: See Chart
Water Source: Municipal Water
Chlorinated: Yes

Collection Date: September 27 & 29, 2016
Collection Time: See Chart
Collected by: Angelo E. Finateri
Potable: Yes
Grab/Composite: Grab
Receipt Temp:

Sample #	Harry Hoag School Sample Point	Collection Time	Date	Test Result (mg/l)	MCL (mg/l)	Qualifiers	Method
23	Fountain #3 counter	5:30AM	9/27/16	0.002	0.015		SM3113B
1	Sink #3 rest room	5:34AM	9/29/16	0.016	0.015	X	SM3113B
10	Sink #4 rest room	5:31AM	9/27/16	0.008	0.015		SM3113B
32	Sink #4 counter	5:33AM	9/27/16	0.004	0.015		SM3113B
38	Fountain #4 counter	5:32AM	9/27/16	0.017	0.015	X	SM3113B
34	Fountain #5 counter	5:35AM	9/27/16	0.037	0.015	X	SM3113B
100	Sink #5 counter	5:35AM	9/27/16	0.008	0.015		SM3113B
8	Sink #5 rest room	5:34AM	9/27/16	0.010	0.015		SM3113B
40	Sink #6 rest room	5:37AM	9/27/16	0.020	0.015	X	SM3113B
22	Sink #6 counter	5:38AM	9/27/16	0.031	0.015	X	SM3113B
57	Fountain #6 counter	5:38AM	9/27/16	0.050	0.015	X	SM3113B
118	Fountain #7 counter	5:40AM	9/27/16	0.038	0.015	X	SM3113B
107	Sink #7 counter	5:40AM	9/27/16	0.013	0.015		SM3113B
97	Sink #7 rest room	5:39AM	9/27/16	0.069	0.015	X	SM3113B
61	Sink #8 counter	5:43AM	9/27/16	0.064	0.015	X	SM3113B
36	Fountain #8 counter	5:42AM	9/27/16	0.022	0.015	X	SM3113B
104	Sink #8 rest room	5:41AM	9/27/16	0.009	0.015		SM3113B
120	Sink Girls RR by #9 first sink from door	5:44AM	9/27/16	0.003	0.015		SM3113B
11	Sink Girls RR by #9 second sink from door	5:44AM	9/27/16	0.001	0.015		SM3113B
3	Sink Closet by #9 basin sink	5:47AM	9/27/16	0.006	0.015		SM3113B
76	Sink Boys RR by #9 first sink from door	5:45AM	9/27/16	0.004	0.015		SM3113B
54	Sink Boys RR by #9 second sink from door	5:46AM	9/27/16	0.042	0.015	X	SM3113B
98	Sink #10 counter work room	5:48AM	9/27/16	0.007	0.015		SM3113B
91	Sink #60 rest room	5:51AM	9/27/16	0.002	0.015		SM3113B

CERTIFICATE OF ANALYSIS

Fulmont Laboratory & Consultants
 219 Noonan Road
 Ft. Johnson, New York 12070
 Phone/Fax: (518) 842-5171

Date: November 20, 2016
Sample ID: 16096
Date Analyzed: November 17, 2016
WO Number: 160927096

Customer: Ft. Plain Central School District
Address: 25 High Street, Ft. Plain, New York 13339
Sample Location: Harry Hoag Elementary School
Sample Point: See Chart
Water Source: Municipal Water
Chlorinated: Yes

Collection Date: September 27 & 29, 2016
Collection Time: See Chart
Collected by: Angelo E. Finateri
Potable: Yes
Grab/Composite: Grab
Receipt Temp:

Sample #	Harry Hoag School Sample Point		Collection Time	Date	Test Result (mg/l)	MCL (mg/l)	Qualifiers	Method
18	Sink	#59 counter conference room	7:05AM	9/27/16	0.004	0.015		SM3113B
109	Sink	#59 rest room	5:50AM	9/27/16	0.006	0.015		SM3113B
2	Sink	#57 rest room	5:53AM	9/27/16	0.008	0.015		SM3113B
28	Sink	#57 counter	5:53AM	9/27/16	0.003	0.015		SM3113B
27	Sink	#57 exam room	5:54AM	9/27/16	0.003	0.015		SM3113B
30	Sink	Girls RR by #57 first sink from door	5:55AM	9/27/16	0.002	0.015		SM3113B
64	Sink	Girls RR by #57 second sink from door	5:55AM	9/27/16	0.002	0.015		SM3113B
113	Sink	Closet by #57 basin sink	5:56AM	9/27/16	0.002	0.015		SM3113B
20	Sink	Boys RR by #57 first sink from door	5:57AM	9/27/16	0.003	0.015		SM3113B
15	Sink	Boys RR by #57 second sink from door	5:57AM	9/27/16	0.002	0.015		SM3113B
108	Sink	Boys RR by #57 third sink from door	5:58AM	9/27/16	0.001	0.015		SM3113B
21	Fountain	Hallway by #57	5:59AM	9/27/16	<0.001	0.015		SM3113B
58	Sink	#45 & #46 work room counter	6:01AM	9/27/16	0.009	0.015		SM3113B
49	Sink	RR by #45 wall	6:02AM	9/27/16	0.006	0.015		SM3113B
24	Sink	Closet by #45 basin	6:02AM	9/27/16	0.092	0.015	X	SM3113B
7	Sink	#44 straight in from door	6:03AM	9/27/16	0.017	0.015	X	SM3113B
117	Sink	#43 straight in from door	6:03AM	9/27/16	0.032	0.015	X	SM3113B
5	Sink	#41 straight in from door	6:05AM	9/27/16	0.036	0.015	X	SM3113B
111	Fountain	Hallway by #34	6:07AM	9/27/16	0.006	0.015		SM3113B
16	Fountain	Hallway by #25	6:08AM	9/27/16	0.002	0.015		SM3113B
29	Sink	Boys RR by #25 first sink from door	6:08AM	9/27/16	0.016	0.015	X	SM3113B
115	Sink	Boys RR by #25 second sink from door	6:09AM	9/27/16	0.004	0.015		SM3113B
62	Sink	Boys RR by #25 third sink from door	6:09AM	9/27/16	0.002	0.015		SM3113B
19	Sink	Closet by #25 basin	6:10AM	9/27/16	0.002	0.015		SM3113B

CERTIFICATE OF ANALYSIS

Fulmont Laboratory & Consultants
 219 Noonan Road
 Ft. Johnson, New York 12070
 Phone/Fax: (518) 842-5171

Date: November 20, 2016

Sample ID: 16096

Date Analyzed: November 17, 2016

WO Number: 160927096

Customer: Ft. Plain Central School District
 Address: 25 High Street, Ft. Plain, New York 13339
 Sample Location: Harry Hoag Elementary School
 Sample Point: See Chart
 Water Source: Municipal Water
 Chlorinated: Yes

Collection Date: September 27 & 29, 2016
 Collection Time: See Chart
 Collected by: Angelo E. Finateri
 Potable: Yes
 Grab/Composite: Grab
 Receipt Temp:

Sample #	Harry Hoag School Sample Point		Collection Time	Date	Test Result (mg/l)	MCL (mg/l)	Qualifiers	Method
51	Sink	Girls RR by #25 first sink from door	6:10AM	9/27/16	0.002	0.015		SM3113B
6	Sink	Girls RR by #25 second sink from door	6:11AM	9/27/16	0.001	0.015		SM3113B
41	Fountain	Hallway by #68	6:16AM	9/27/16	0.004	0.015		SM3113B
65	Sink	Closet by #68 basin	6:21AM	9/27/16	0.002	0.015		SM3113B
86	Sink	#68 women's RR	6:39AM	9/27/16	0.007	0.015		SM3113B
66	Sink	#68 men's RR	6:40AM	9/27/16	0.003	0.015		SM3113B
77	Sink	#68 Superintendent's office rest room	6:42AM	9/27/16	0.010	0.015		SM3113B
79	Sink	Girls RR by #61 first sink from door	6:17AM	9/27/16	0.027	0.015	X	SM3113B
60	Sink	Girls RR by #61 second sink from door	6:18AM	9/27/16	0.012	0.015		SM3113B
68	Sink	Girls RR by #61 third sink from door	6:18AM	9/27/16	0.015	0.015	X	SM3113B
90	Sink	Women's Fac RR by #61 wall	6:21AM	9/27/16	0.026	0.015	X	SM3113B
84	Sink	Men's Fac RR by #61 wall	6:25AM	9/27/16	0.053	0.015	X	SM3113B
33	Sink	Boys RR by #61 first sink from door	6:23AM	9/27/16	0.034	0.015	X	SM3113B
74	Sink	Boys RR by #61 second sink from door	6:23AM	9/27/16	0.018	0.015	X	SM3113B
54	Sink	Boys RR by #61 third sink from door	6:24AM	9/27/16	0.001	0.015		SM3113B
106	Sink	#61 first to right of door in counter	6:26AM	9/27/16	0.170	0.015	X	SM3113B
114	Sink	#61 second to right of door in counter	5:37AM	9/29/16	0.150	0.015	X	SM3113B
85	Sink	#61 third to right of door in counter	6:27AM	9/27/16	0.044	0.015	X	SM3113B
96	Sink	#61 fourth to right of door in counter	6:28AM	9/27/16	0.280	0.015	X	SM3113B
69	Sink	#62 first left of wall sink	6:30AM	9/27/16	0.170	0.015	X	SM3113B
105	Sink	#62 second to left of wall sink	6:30AM	9/27/16	0.049	0.015	X	SM3113B
95	Sink	#62 third to left of wall sink	6:31AM	9/27/16	0.810	0.015	X	SM3113B
73	Sink	#62 fourth to left of wall sink	6:29AM	9/27/16	0.072	0.015	X	SM3113B
59	Sink	#63 counter	6:36AM	9/27/16	0.005	0.015		SM3113B

CERTIFICATE OF ANALYSIS

Fulmont Laboratory & Consultants
 219 Noonan Road
 Ft. Johnson, New York 12070
 Phone/Fax: (518) 842-5171

Date: November 20, 2016
Sample ID: 16096
Date Analyzed: November 17, 2016
WO Number: 160927096

<i>Customer:</i> Ft. Plain Central School District	<i>Collection Date:</i> September 27 & 29, 2016
<i>Address:</i> 25 High Street, Ft. Plain, New York 13339	<i>Collection Time:</i> See Chart
<i>Sample Location:</i> Harry Hoag Elementary School	<i>Collected by:</i> Angelo E. Finateri
<i>Sample Point:</i> See Chart	<i>Potable:</i> Yes
<i>Water Source:</i> Municipal Water	<i>Grab/Composite:</i> Grab
<i>Chlorinated:</i> Yes	<i>Receipt Temp:</i>

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Comments:

Not all test results are within acceptable limits, please consult chart. Test procedures for all analyses meet NELAC requirements unless noted. If you have any questions, please call the laboratory.

Qualifiers Key:

X - Exceeds maximum contamination limit	R – Duplication outside acceptance limits	H – Hold time exceeded
T - Temperature outside specifications	A – Sample contained air bubble or headspace	B – Analyte detected in blank
S (+/-) Lab control sample outside acceptable limits	M (+/-) Matrix spike recovery outside acceptance limits	
(+) Result may be biased high		
(-) Result may be biased low		

Legend:

< = Less than
 > = Greater than
 ≈ = Approximately
 NP = Not Provided
 mg/l = milligrams per liter = ppm
 ppm = parts per million
 µg/l = micrograms per liter = ppb
 ppb = parts per billion
 gpg = grains per gallon
 MCL = Maximum Contaminant Level
 SM = Standard Methods For the Examination of Water and Wastewater

Reviewed by Angelo E. Finateri Angelo E. Finateri

Environmental Laboratory NYSDOH E.L.A.P. #10350