

# CERTIFICATE OF ANALYSIS

Fulmont Laboratory & Consultants  
 219 Noonan Road  
 Ft. Johnson, New York 12070  
 Phone/Fax: (518) 842-5171

*Date:* December 1, 2016  
*Sample ID:* 16126  
*Date Analyzed:* November 29, 2016  
*WO Number:* 1601005126

<i>Customer:</i> Ft. Plain Central School District	<i>Collection Date:</i> October 5, 2016
<i>Address:</i> 1 West Street, Ft. Plain, New York 13339	<i>Collection Time:</i> See Chart
<i>Sample Location:</i> Ft. Plain High School & Harry Hoag Elementary School	<i>Collected by:</i> Angelo E. Finateri
<i>Sample Point:</i> See Chart	<i>Potable:</i> Yes
<i>Water Source:</i> Municipal Water	<i>Grab/Composite:</i> Grab
<i>Chlorinated:</i> Yes	<i>Receipt Temp:</i>

Sample #	Ft. Plain High School Sample Point	Collection Time	Date	Test Result (mg/l)	MCL (mg/l)	Qualifier	Method
85	Sink #113 rest room	5:00AM	10/5/16	0.022	0.015	X	SM3113B
56	Sink #113 counter right	5:01AM	10/5/16	0.005	0.015		SM3113B
15	Sink #113 counter left	5:02AM	10/5/16	0.006	0.015		SM3113B
97	Fountain Hallway by #111 facing right	5:04 AM	10/5/16	0.002	0.015		SM3113B
116	Fountain Hallway by #111 facing left	5:04AM	10/5/16	0.002	0.015		SM3113B
27	Fountain #111 facing right	5:05AM	10/5/16	0.003	0.015		SM3113B
96	Fountain #111 facing left	5:05AM	10/5/16	0.002	0.015		SM3113B
6	Sink Lobby Closet basin	5:11AM	10/5/16	0.006	0.015		SM3113B
58	Fountain #111 facing left	5:12AM	10/5/16	0.001	0.015		SM3113B
94	Sink Lobby men's restroom left	5:12AM	10/5/16	0.014	0.015		SM3113B
26	Sink Lobby men's restroom right	5:13AM	10/5/16	0.005	0.015		SM3113B
5	Sink Lobby Womens rest room left	5:14AM	10/5/16	0.005	0.015		SM3113B
38	Sink Lobby Women's rest room right	5:14AM	10/5/16	0.005	0.015		SM3113B
111	Sink Boys PE office	5:16AM	10/5/16	0.002	0.015		SM3113B
59	Sink Boys Locker room left	5:09AM	10/5/16	0.006	0.015		SM3113B
81	Sink Boys Locker room right	5:09AM	10/5/16	0.012	0.015		SM3113B
117	Sink Girls PE office	5:18AM	10/5/16	0.001	0.015		SM3113B
92	Sink Girls Locker room left	5:07AM	10/5/16	0.004	0.015		SM3113B
84	Sink Girls Locker room right	5:08AM	10/5/16	0.003	0.015		SM3113B
7	Fountain Gym Hallway by girls PE office	5:17AM	10/5/16	0.001	0.015		SM3113B
75	Sink Library work room	5:19AM	10/5/16	0.002	0.015		SM3113B
103	Sink Kitchen rest room	5:33AM	10/5/16	0.003	0.015		SM3113B
	Ice Machine Kitchen	5:23AM	10/5/16	<0.001	0.015		SM3113B
19	Sink Kitchen right of ice machine	5:21AM	10/5/16	0.003	0.015		SM3113B

# CERTIFICATE OF ANALYSIS

Fulmont Laboratory & Consultants  
 219 Noonan Road  
 Ft. Johnson, New York 12070  
 Phone/Fax: (518) 842-5171

*Date:* December 1, 2016  
*Sample ID:* 16126  
*Date Analyzed:* November 29, 2016  
*WO Number:* 1601005126

<i>Customer:</i>	Ft. Plain Central School District	<i>Collection Date:</i>	October 5, 2016
<i>Address:</i>	1 West Street, Ft. Plain, New York 13339	<i>Collection Time:</i>	See Chart
<i>Sample Location:</i>	Ft. Plain High School & Harry Hoag Elementary School	<i>Collected by:</i>	Angelo E. Finateri
<i>Sample Point:</i>	See Chart	<i>Potable:</i>	Yes
<i>Water Source:</i>	Municipal Water	<i>Grab/Composite:</i>	Grab
<i>Chlorinated:</i>	Yes	<i>Receipt Temp:</i>	

Sample #	<u>Ft. Plain High School Sample Point</u>			<u>Collection Time</u>	<u>Date</u>	<u>Test Result (mg/l)</u>	<u>MCL (mg/l)</u>	<u>Qualifiers</u>	<u>Method</u>
20	Sink	Kitchen	left of ice machine	5:25AM	10/5/16	0.002	0.015		SM3113B
115	Sink	Kitchen	basin	5:29AM	10/5/16	0.016	0.015	X	SM3113B
34	Sink	Kitchen	left of basin	5:28AM	10/5/16	0.006	0.015		SM3113B
23	outlet	Kitchen	pre rinse dish washer	5:27AM	10/5/16	0.004	0.015		SM3113B
99	Sink	Kitchen	two gang right	5:26AM	10/5/16	0.002	0.015		SM3113B
36	Sink	Kitchen	two gang left	5:25AM	10/5/16	0.002	0.015		SM3113B
16	outlet	Kitchen	steam kettle	5:31AM	10/5/16	0.004	0.015		SM3113B
53	Outlet	Kitchen	steam table	5:30AM	10/5/16	0.013	0.015		SM3113B
89	Sink	Kitchen	serving line	5:32AM	10/5/16	0.005	0.015		SM3113B
120	Sink	Nurse	rest room	5:40AM	10/5/16	0.002	0.015		SM3113B
49	Sink	Nurse	counter	5:39AM	10/5/16	0.001	0.015		SM3113B
86	Sink	Nurse	exam room	5:37AM	10/5/16	0.008	0.015		SM3113B
14	Sink	Main	rest room	5:41AM	10/5/16	0.001	0.015		SM3113B
107	Sink	Faculty		5:35AM	10/5/16	0.002	0.015		SM3113B
37	Sink	Faculty	rest room by faculty room	5:36AM	10/5/16	0.003	0.015		SM3113B
11	Sink	1st Floor Boys RR	closet	5:42AM	10/5/16	0.009	0.015		SM3113B
40	Sink	1st Floor Boys RR	left	5:43AM	10/5/16	0.003	0.015		SM3113B
30	Sink	1st Floor Boys RR	right	5:43AM	10/5/16	0.004	0.015		SM3113B
42	Fountain	1st Floor by boys basement		5:44AM	10/5/16	<0.001	0.015		SM3113B
24	Sink	1st Floor Girls RR	left	5:45AM	10/5/16	0.005	0.015		SM3113B
10	Sink	1st Floor Girls RR	right	5:45AM	10/5/16	0.002	0.015		SM3113B
46	Sink	#106	1st left of door	5:46AM	10/5/16	0.004	0.015		SM3113B
3	Sink	#106	2nd left of door	5:46AM	10/5/16	0.002	0.015		SM3113B
61	Sink	#106	straight in to the right	5:47AM	10/5/16	0.004	0.015		SM3113B

# CERTIFICATE OF ANALYSIS

Fulmont Laboratory & Consultants  
 219 Noonan Road  
 Ft. Johnson, New York 12070  
 Phone/Fax: (518) 842-5171

*Date:* December 1, 2016  
*Sample ID:* 16126  
*Date Analyzed:* November 29, 2016  
*WO Number:* 1601005126

<i>Customer:</i> Ft. Plain Central School District	<i>Collection Date:</i> October 5, 2016
<i>Address:</i> 1 West Street, Ft. Plain, New York 13339	<i>Collection Time:</i> See Chart
<i>Sample Location:</i> Ft. Plain High School & Harry Hoag Elementary School	<i>Collected by:</i> Angelo E. Finateri
<i>Sample Point:</i> See Chart	<i>Potable:</i> Yes
<i>Water Source:</i> Municipal Water	<i>Grab/Composite:</i> Grab
<i>Chlorinated:</i> Yes	<i>Receipt Temp:</i>

Sample #	Ft. Plain High School Sample Point	Collection Time	Date	Test Result (mg/l)	MCL (mg/l)	Qualifiers	Method
52	Sink #107 1st to the right	5:48AM	10/5/16	0.005	0.015		SM3113B
105	Sink #107 2nd to the right	5:49AM	10/5/16	0.004	0.015		SM3113B
12	outlet Green House right of door	5:53AM	10/5/16	0.003	0.015		SM3113B
31	Sink #109 straight in from hallway door	5:51AM	10/5/16	0.004	0.015		SM3113B
9	Sink #110 on right side from hallway door	5:50AM	10/5/16	0.001	0.015		SM3113B
28	Sink Boiler Room next to rest room	5:58AM	10/5/16	0.027	0.015	X	SM3113B
8	Sink #002 counter right of door	6:00AM	10/5/16	0.010	0.015		SM3113B
13	Sink #002 rest room	6:01AM	10/5/16	0.004	0.015		SM3113B
77	Sink Faculty RR	6:01AM	10/5/16	0.002	0.015		SM3113B
2	Sink #001 counter left of door	6:02AM	10/5/16	0.002	0.015		SM3113B
82	Sink Garth Shop left of door	6:04AM	10/5/16	0.071	0.015	X	SM3113B
64	outlet Garth Shop Garage right of overhead door	6:04AM	10/5/16	0.020	0.015	X	SM3113B
51	Sink # 201 1st straight in counter	6:49AM	10/5/16	0.007	0.015		SM3113B
4	Sink #201 2nd straight in counter	6:50AM	10/5/16	0.031	0.015	X	SM3113B
62	Sink #201 1st left of door counter	6:51AM	10/5/16	0.008	0.015		SM3113B
22	Sink #201 2nd left of door counter	6:51AM	10/5/16	0.013	0.015		SM3113B
18	Sink #203 straight in from door hood	6:44AM	10/5/16	0.063	0.015	X	SM3113B
63	Sink #203 straight in from door island 1st	6:46AM	10/5/16	0.004	0.015		SM3113B
1	Sink #203 straight in from door island 2nd	6:46AM	10/5/16	0.008	0.015		SM3113B
54	Sink #203 left of door counter 1st	6:48 AM	10/5/16	0.052	0.015	X	SM3113B
78	Sink #203 left of door counter 2nd	6:47AM	10/5/16	0.031	0.015	X	SM3113B
67	Sink 2nd Floor Boys RR left	6:42AM	10/5/16	0.005	0.015		SM3113B
101	Sink 2nd Floor Boys RR middle	6:42AM	10/5/16	0.005	0.015		SM3113B
50	Sink 2nd Floor Boys RR right	6:43AM	10/5/16	0.006	0.015		SM3113B

# CERTIFICATE OF ANALYSIS

Fulmont Laboratory & Consultants  
 219 Noonan Road  
 Ft. Johnson, New York 12070  
 Phone/Fax: (518) 842-5171

*Date:* December 1, 2016  
*Sample ID:* 16126  
*Date Analyzed:* November 29, 2016  
*WO Number:* 1601005126

<i>Customer:</i> Ft. Plain Central School District	<i>Collection Date:</i> October 5, 2016
<i>Address:</i> 1 West Street, Ft. Plain, New York 13339	<i>Collection Time:</i> See Chart
<i>Sample Location:</i> Ft. Plain High School & Harry Hoag Elementary School	<i>Collected by:</i> Angelo E. Finateri
<i>Sample Point:</i> See Chart	<i>Potable:</i> Yes
<i>Water Source:</i> Municipal Water	<i>Grab/Composite:</i> Grab
<i>Chlorinated:</i> Yes	<i>Receipt Temp:</i>

Sample #	Ft. Plain High School Sample Point	Collection Time	Date	Test Result (mg/l)	MCL (mg/l)	Qualifiers	Method
44	Sink 2nd Floor Faculty RR	6:41AM	10/5/16	0.002	0.015		SM3113B
55	Sink 2nd Floor Girls RR 1st from door	6:39AM	10/5/16	0.005	0.015		SM3113B
87	Sink 2nd Floor Girls RR 2nd from door	6:39AM	10/5/16	0.004	0.015		SM3113B
39	Sink 2nd Floor Girls RR 3rd from door	6:40AM	10/5/16	0.010	0.015		SM3113B
110	Fountain 2nd Floor by faculty rr	6:38AM	10/5/16	<0.001	0.015		SM3113B
90	Sink #208 1st left of door	6:36AM	10/5/16	0.008	0.015		SM3113B
17	Sink #208 2nd left of door	6:37AM	10/5/16	0.009	0.015		SM3113B
95	Sink #208 3rd left of door	6:37AM	10/5/16	0.006	0.015		SM3113B
65	Sink #301 left of door	6:32AM	10/5/16	0.011	0.015		SM3113B
21	Sink #302 right of door	6:31AM	10/5/16	0.008	0.015		SM3113B
88	Sink #303 row 1 1st island	6:24AM	10/5/16	0.011	0.015		SM3113B
25	Sink #303 row 1 2nd island	6:28AM	10/5/16	0.032	0.015	X	SM3113B
83	Sink #303 row 1 3rd island	6:28AM	10/5/16	0.023	0.015	X	SM3113B
29	Sink #303 row 2 1st island	6:30AM	10/5/16	0.022	0.015	X	SM3113B
66	Sink #303 row2 2nd island	6:29AM	10/5/16	0.030	0.015	X	SM3113B
73	Sink #303 row2 3rd island	6:29AM	10/5/16	0.018	0.015	X	SM3113B
93	Sink #303 far left corner	6:30AM	10/5/16	0.018	0.015	X	SM3113B
33	Sink #304 row 1 1st island	6:18AM	10/5/16	0.017	0.015	X	SM3113B
69	Sink #304 row 1 2nd island	6:19AM	10/5/16	0.017	0.015	X	SM3113B
79	Sink #304 row 1 3rd island	6:20AM	10/5/16	0.015	0.015	X	SM3113B
119	Sink #304 row 2 1st island	6:23AM	10/5/16	0.031	0.015	X	SM3113B
41	Sink #304 row 2 2nd island	6:21AM	10/5/16	0.022	0.015	X	SM3113B
70	Sink #304 row 2 3rd island	6:21AM	10/5/16	0.009	0.015		SM3113B
100	Sink #304 far right corner	6:17AM	10/5/16	0.016	0.015	X	SM3113B

# CERTIFICATE OF ANALYSIS

Fulmont Laboratory & Consultants  
 219 Noonan Road  
 Ft. Johnson, New York 12070  
 Phone/Fax: (518) 842-5171

*Date:* December 1, 2016  
*Sample ID:* 16126  
*Date Analyzed:* November 29, 2016  
*WO Number:* 1601005126

<i>Customer:</i> Ft. Plain Central School District	<i>Collection Date:</i> October 5, 2016
<i>Address:</i> 1 West Street, Ft. Plain, New York 13339	<i>Collection Time:</i> See Chart
<i>Sample Location:</i> Ft. Plain High School & Harry Hoag Elementary School	<i>Collected by:</i> Angelo E. Finateri
<i>Sample Point:</i> See Chart	<i>Potable:</i> Yes
<i>Water Source:</i> Municipal Water	<i>Grab/Composite:</i> Grab
<i>Chlorinated:</i> Yes	<i>Receipt Temp:</i>

Sample #	Ft. Plain High School Sample Point	Collection Time	Date	Test Result (mg/l)	MCL (mg/l)	Qualifiers	Method
74	Sink #304 far right corner hood	6:18AM	10/5/16	0.057	0.015	X	SM3113B
109	Sink #307 left of door	6:16AM	10/5/16	0.009	0.015		SM3113B
114	Sink 3rd Floor Boys RR left	6:14AM	10/5/16	0.006	0.015		SM3113B
43	Sink 3rd Floor Boys RR middle	6:15AM	10/5/16	0.009	0.015		SM3113B
76	Sink 3rd Floor Boys RR right	6:15AM	10/5/16	0.010	0.015		SM3113B
32	Sink 3rd Floor Faculty RR	6:13AM	10/5/16	0.001	0.015		SM3113B
35	Sink 3rd Floor Girls RR 1st from door	6:07AM	10/5/16	0.009	0.015		SM3113B
113	Sink 3rd Floor Girls RR 2nd from door	6:08AM	10/5/16	0.004	0.015		SM3113B
45	Sink 3rd Floor Girls RR 3rd from door	6:09AM	10/5/16	0.004	0.015		SM3113B
106	Fountain 3rd Floor by faculty rr	6:06AM	10/5/16	<0.001	0.015		SM3113B
68	Sink 3rd Floor Closet basin	6:35AM	10/5/16	0.011	0.015		SM3113B
	Harry Hoag Retest						
118	Sink Boys RR by #9 2nd sink from door	7:02AM	10/5/16	0.001	0.015		SM3113B
112	Sink Boys RR by #62 2nd sink from door	7:05AM	10/5/16	0.037	0.015	X	SM3113B

# CERTIFICATE OF ANALYSIS

Fulmont Laboratory & Consultants  
 219 Noonan Road  
 Ft. Johnson, New York 12070  
 Phone/Fax: (518) 842-5171

*Date:* December 1, 2016  
*Sample ID:* 16126  
*Date Analyzed:* November 29, 2016  
*WO Number:* 1601005126

<i>Customer:</i> Ft. Plain Central School District	<i>Collection Date:</i> October 5, 2016
<i>Address:</i> 1 West Street, Ft. Plain, New York 13339	<i>Collection Time:</i> See Chart
<i>Sample Location:</i> Ft. Plain High School & Harry Hoag Elementary School	<i>Collected by:</i> Angelo E. Finateri
<i>Sample Point:</i> See Chart	<i>Potable:</i> Yes
<i>Water Source:</i> Municipal Water	<i>Grab/Composite:</i> Grab
<i>Chlorinated:</i> Yes	<i>Receipt Temp:</i>

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

**Comments:**

Not all test results are within acceptable limits, please consult chart. Test procedures for all analyses meet NELAC requirements unless noted. If you have any questions, please call the laboratory.

**Qualifiers Key:**

<b>X</b> - Exceeds maximum contamination limit	<b>R</b> – Duplication outside acceptance limits	<b>H</b> – Hold time exceeded
<b>T</b> - Temperature outside specifications	<b>A</b> – Sample contained air bubble or headspace	<b>B</b> – Analyte detected in blank
<b>S</b> (+/-) Lab control sample outside acceptable limits	<b>M</b> (+/-) Matrix spike recovery outside acceptance limits	
(+) Result may be biased high		
(-) Result may be biased low		

**Legend:**

< = Less than  
 > = Greater than  
 ≈ = Approximately  
 NP = Not Provided  
 mg/l = milligrams per liter = ppm  
 ppm = parts per million  
 µg/l = micrograms per liter = ppb  
 ppb = parts per billion  
 gpg = grains per gallon  
 MCL = Maximum Contaminant Level  
 SM = Standard Methods For the Examination of Water and Wastewater

**Reviewed by Angelo E. Finateri** Angelo E. Finateri

Environmental Laboratory NYSDOH E.L.A.P. #10350